



2025-2026 Annual Fugitive Dust Control Report

**Inactive Coal Combustion Residuals
Impoundment**


City of Ames

July 9, 2026

Certification

Annual Fugitive Dust Control Report
Inactive CCR Impoundment
Ames, Iowa
City of Ames

I certify this Annual Fugitive Dust Control Report meets the requirements of 40 CFR §257.80(c).

	I hereby certify that this engineering document was prepared by me or under my direct personal supervision and that I am a duly licensed Professional Engineer under the laws of the State of Iowa.	
	 Michael J. Alowitz, P.E.	 Date
	License Number: 18160	
	My license renewal date is: December 31, 2026	
	Pages or sheets covered by this seal: Entire Document	

Contents

1.	Rule Requirement – Federal CCR Rule §257.80(c)	1
2.	Description of the actions taken to control CCR fugitive dust	1
2.1	Haul Roads	1
2.2	Construction	1
3.	Record of all citizen complaints	1
4.	Summary of corrective measures	2
5.	Reference	2

1. Rule Requirement – Federal CCR Rule §257.80(c)

Under Federal Rule §257.80(c), the City of Ames prepared an Annual Coal Combustion Residuals (CCR) Fugitive Dust Control Report within 14 months of placing the initial CCR Fugitive Dust Control Plan developed by Wenck Associates in October 2015 in the inactive impoundment's operating record. A revised CCR Fugitive Dust Control Plan was issued in April 2019 (SCS Engineers [SCS], 2019). Subsequent annual reports are due one year from the previous report date.

This Annual Fugitive Dust Control report is for May 2025 through April 2026.

The annual fugitive dust control report includes:

1. A description of the actions taken to control CCR fugitive dust (Section 2).
2. A record of all citizen complaints (Section 3).
3. A summary of any corrective measures taken to address dust control (Section 4).

A copy of this report will be placed in the operating record as required under §257.105(g)(2).

An updated Fugitive Dust Control Plan will be issued in 2026 to reflect changes in site conditions.

This report was prepared by GHD Services Inc. (GHD) for City of Ames and may only be used and relied on by City of Ames for the purpose agreed between GHD and City of Ames. GHD otherwise disclaims responsibility to any person other than City of Ames arising in connection with this report. GHD also excludes implied warranties and conditions, to the extent legally permissible.

2. Description of the actions taken to control CCR fugitive dust

2.1 Haul Roads

The former CCR impoundment is closed with general construction completed in 2025. Perimeter roads remain a potential dust source but the dust would not be CCR-related.

2.2 Construction

During the period of this report, closure construction was completed for the inactive impoundment. This included consolidating materials and closing a portion of the inactive impoundment by removal of all CCR. During construction, dust was minimized by the application of water. As of June 2025, the CCR was under cover and CCR was no longer exposed to wind or vehicle traffic.

3. Record of all citizen complaints

A procedure to log citizen complaints is identified in Section 6 of the CCR Fugitive Dust Control Plan, updated April 2019 (SCS, 2019).

No citizen complaints were received during the 2025-2026 reporting period.

4. Summary of corrective measures

No fugitive dust-related corrective measures were required during the reporting period.

5. Reference

GHD Services, Inc. 2024-2025 Annual Fugitive Dust Control Report. July 30, 2025.

SCS Engineers, 2019. Coal Combustion Residuals (CCR) Fugitive Dust Control Plan. April.



ghd.com

→ **The Power of Commitment**