



NOTES:

1. On buildings where service passes over but does not attach, the vertical clearance must be 11' if accessible or 3.5' if inaccessible.

<p>CITY OF AMES ELECTRIC SERVICES</p>	<p>MINIMUM CLEARANCE FOR ELECTRICAL SERVICES 300V AND LESS</p>	<p>ELECTRIC METERING</p>
<p>REVISED: MEI 6-20-17</p>		<p>EM700</p>
<p>APPROVED:</p>		<p>PAGE 1 OF 1</p>