



1. Pre-assembled multiple meter equipment shall be supplied by customer. All equipment shall be UL listed.
2. Working space in front of service entrance equipment and meter sockets shall be in accordance with NEC 110.26.
3. Apartments or suites shall be individually labelled with a permanent/weatherproof label.
4. Unused meter sockets shall have a plastic protective cover and shall be sealed.

<p style="text-align: center;">CITY OF AMES ELECTRIC SERVICES</p>	<p>MULTI-TENANT COMMERCIAL METERING</p>	<p>ELECTRIC METER</p>
<p>REVISED: MEI 6/15/18</p>		<p>EM711</p>
<p>APPROVED:</p>		<p>PAGE 1 OF 1</p>